

1.1 ADDENDUM

- .1 The following changes to the drawings and specifications are to be incorporated into the Bid Documents.
 - .1 Section 01 40 00, Clause 3.1
 - .1 **Revise** Item No. 1 description in Portland Concrete Testing table to read as follows:
“Cast-in-Place Foundations – Large Pour”
 - .2 **Revise** Item No. 2 description in Portland Concrete Testing table to read as follows:
“Cast-in-Place Foundations – Small Pour”

1.2 CLARIFICATIONS

- .1 All instances in the specifications where precast concrete is noted will be replaced with cast-in-place concrete foundations. Contractor responsible for design of reinforced concrete in accordance with note 7.0 on Drawing 4-01.
- .2 No demising wall between salt and sand storage is required.
- .3 Rock excavation is not anticipated in this project. If such conditions are encountered during construction, the work required for its breaking and removal above and beyond normal excavation requirements shall be considered as extra work in accordance with the requirements outlined in the specifications.
- .4 The site is accessible from Loch Lomond Road using the Airport Service Road. The site is outside of the secure area and there no restrictions in accessing the site.
- .5 The site will be available to begin construction July 30, 2018.

END OF SECTION

